

ITS PLAN LAYOUT LEGEND (NOMENCLATURE)				REFERENCE PROJECT NO	FISCAL YEAR	SHEET NO																																																																																																																																																																																																																																																																																																																																																														
REQUIRED ITS CONDUIT STANDARD LEGEND <table><tr><td>A</td><td>CONDUIT, UNDERGROUND, NON-METALLIC, 2 INCH</td></tr><tr><td>B</td><td>CONDUIT, RIGID METALLIC, 2 INCH</td></tr><tr><td>C</td><td>CONDUIT, UNDERGROUND, NON-METALLIC, 1 1/2 INCH</td></tr><tr><td>D</td><td>CONDUIT, UNDERGROUND, NON-METALLIC, 2 1/2 INCH</td></tr><tr><td>F</td><td>CONDUIT, UNDERGROUND, NON-METALLIC, 3 INCH</td></tr><tr><td>G</td><td>CONDUIT, UNDERGROUND, NON-METALLIC, 3 1/2 INCH</td></tr><tr><td>H</td><td>CONDUIT, UNDERGROUND, NON-METALLIC, 4 INCH</td></tr><tr><td>J</td><td>*(IF REQUIRED FOR THE ITS DESIGN)</td></tr><tr><td>K</td><td>*(IF REQUIRED FOR THE ITS DESIGN)</td></tr><tr><td>SP</td><td>SPARE / EMPTY CONDUIT</td></tr></table> ITS CONDUIT OPTIONS <table><tr><td>*</td><td>CONDUIT, EXPOSED, NON-METALLIC, 1 1/2 INCH</td></tr><tr><td>*</td><td>CONDUIT, EXPOSED, NON-METALLIC, 2 INCH</td></tr><tr><td>*</td><td>CONDUIT, EXPOSED, NON-METALLIC, 2 1/2 INCH</td></tr><tr><td>*</td><td>CONDUIT, EXPOSED, NON-METALLIC, 3 INCH</td></tr><tr><td>*</td><td>CONDUIT, EXPOSED, NON-METALLIC, 3 1/2 INCH</td></tr><tr><td>*</td><td>CONDUIT, EXPOSED, NON-METALLIC, 4 INCH</td></tr><tr><td>*</td><td>CONDUIT, UNDERGROUND, NON-METALLIC, 5 INCH</td></tr><tr><td>*</td><td>CONDUIT, UNDERGROUND, NON-METALLIC, 6 INCH</td></tr><tr><td>*</td><td>CONDUIT, RIGID METALLIC, 2 INCH, ALUMINUM</td></tr><tr><td>*</td><td>CONDUIT, REINFORCED THERMOSETTING RESIN, 2 INCH</td></tr><tr><td>*</td><td>CONDUIT, FRICTION REDUCTION MULTIDUCT SLEEVES, 2 INCH, 2-CELL</td></tr><tr><td>*</td><td>CONDUIT, FRICTION REDUCTION MULTIDUCT SLEEVES, 2 INCH, 3-CELL</td></tr><tr><td>*</td><td>CONDUIT, FRICTION REDUCTION MULTIDUCT SLEEVES, 4 INCH, 3-CELL</td></tr><tr><td>*</td><td>CONDUIT, FRICTION REDUCTION MULTIDUCT SLEEVES, 6 INCH, 3-CELL</td></tr></table> NOTES: 1. ONLY THE "REQUIRED ITS CONDUIT STANDARD LEGEND" BOX SHOULD BE SHOWN IN THE PLAN SET. 2. WITHIN THE "REQUIRED ITS CONDUIT STANDARD LEGEND" BOX, POPULATE ANY LEGEND ITEMS "J" - "N" REQUIRED FOR THE ITS DESIGN. 3. LEGEND ITEMS "J" - "N" SHOULD BE POPULATED FROM THE "ITS CONDUIT OPTIONS" BOX OR ALDOT'S "US ITEMS LIST". 4. WITHIN THE "REQUIRED ITS CONDUIT STANDARD LEGEND" BOX, HIDE ANY LEGEND ITEMS "A-N" NOT REQUIRED FOR THE ITS DESIGN.				A	CONDUIT, UNDERGROUND, NON-METALLIC, 2 INCH	B	CONDUIT, RIGID METALLIC, 2 INCH	C	CONDUIT, UNDERGROUND, NON-METALLIC, 1 1/2 INCH	D	CONDUIT, UNDERGROUND, NON-METALLIC, 2 1/2 INCH	F	CONDUIT, UNDERGROUND, NON-METALLIC, 3 INCH	G	CONDUIT, UNDERGROUND, NON-METALLIC, 3 1/2 INCH	H	CONDUIT, UNDERGROUND, NON-METALLIC, 4 INCH	J	*(IF REQUIRED FOR THE ITS DESIGN)	K	*(IF REQUIRED FOR THE ITS DESIGN)	SP	SPARE / EMPTY CONDUIT	*	CONDUIT, EXPOSED, NON-METALLIC, 1 1/2 INCH	*	CONDUIT, EXPOSED, NON-METALLIC, 2 INCH	*	CONDUIT, EXPOSED, NON-METALLIC, 2 1/2 INCH	*	CONDUIT, EXPOSED, NON-METALLIC, 3 INCH	*	CONDUIT, EXPOSED, NON-METALLIC, 3 1/2 INCH	*	CONDUIT, EXPOSED, NON-METALLIC, 4 INCH	*	CONDUIT, UNDERGROUND, NON-METALLIC, 5 INCH	*	CONDUIT, UNDERGROUND, NON-METALLIC, 6 INCH	*	CONDUIT, RIGID METALLIC, 2 INCH, ALUMINUM	*	CONDUIT, REINFORCED THERMOSETTING RESIN, 2 INCH	*	CONDUIT, FRICTION REDUCTION MULTIDUCT SLEEVES, 2 INCH, 2-CELL	*	CONDUIT, FRICTION REDUCTION MULTIDUCT SLEEVES, 2 INCH, 3-CELL	*	CONDUIT, FRICTION REDUCTION MULTIDUCT SLEEVES, 4 INCH, 3-CELL	*	CONDUIT, FRICTION REDUCTION MULTIDUCT SLEEVES, 6 INCH, 3-CELL	REQUIRED ITS ENCASEMENT STANDARD LEGEND <table><tr><td>E</td><td>6" ELECTRICAL CONDUIT, 1 LINE, TYPE 5 INSTALLATION</td></tr></table> REQUIRED ITS ENCASEMENT COMPREHENSIVE LEGEND <table><tr><td>E01</td><td>2" ELECTRICAL CONDUIT, 1 LINE, TYPE 5 INSTALLATION</td></tr><tr><td>E02</td><td>3" ELECTRICAL CONDUIT, 1 LINE, TYPE 1 INSTALLATION</td></tr><tr><td>E03</td><td>3" ELECTRICAL CONDUIT, 2 LINES, TYPE 1 INSTALLATION</td></tr><tr><td>E04</td><td>3" ELECTRICAL CONDUIT, 1 LINE, TYPE 5 INSTALLATION</td></tr><tr><td>E05</td><td>3" ELECTRICAL CONDUIT, 2 LINES, TYPE 5 INSTALLATION</td></tr><tr><td>E06</td><td>4" ELECTRICAL CONDUIT, 1 LINE, TYPE 1 INSTALLATION</td></tr><tr><td>E07</td><td>4" ELECTRICAL CONDUIT, 2 LINES, TYPE 1 INSTALLATION</td></tr><tr><td>E08</td><td>4" ELECTRICAL CONDUIT, 4 LINES, TYPE 1 INSTALLATION</td></tr><tr><td>E09</td><td>4" ELECTRICAL CONDUIT, 1 LINE, TYPE 5 INSTALLATION</td></tr><tr><td>E10</td><td>4" ELECTRICAL CONDUIT, 2 LINES, TYPE 5 INSTALLATION</td></tr><tr><td>E11</td><td>5" ELECTRICAL CONDUIT, 2 LINES, TYPE 1 INSTALLATION</td></tr><tr><td>E12</td><td>5" ELECTRICAL CONDUIT, 1 LINE, TYPE 5 INSTALLATION</td></tr><tr><td>E13</td><td>5" ELECTRICAL CONDUIT, 2 LINES, TYPE 5 INSTALLATION</td></tr><tr><td>E14</td><td>6" ELECTRICAL CONDUIT, 1 LINE, TYPE 1 INSTALLATION</td></tr><tr><td>E15</td><td>6" ELECTRICAL CONDUIT, 1 LINE, TYPE 5 INSTALLATION</td></tr><tr><td>E16</td><td>6 INCH ELECTRICAL CONDUIT, 2 LINES, TYPE 5 INSTALLATION</td></tr><tr><td>E17</td><td>8" ELECTRICAL CONDUIT, 1 LINE, TYPE 5 INSTALLATION</td></tr><tr><td>E18</td><td>8 INCH ELECTRICAL CONDUIT, 3 LINES, TYPE 5 INSTALLATION</td></tr></table> NOTES: 1. EITHER THE "REQUIRED ITS ENCASEMENT STANDARD LEGEND" BOX OR THE "REQUIRED ITS ENCASEMENT COMPREHENSIVE LEGEND" BOX SHOULD BE SHOWN IN THE PLAN SET. BOTH CANNOT BE USED TOGETHER. 2. THE "REQUIRED ITS ENCASEMENT STANDARD LEGEND" BOX SHOULD BE USED IF THE ITS DESIGN REQUIRES ONLY ONE TYPE OF ENCASEMENT. 3. WITHIN THE "REQUIRED ITS ENCASEMENT STANDARD LEGEND" BOX, PAY ITEM 756A-028 IS USED FOR THE DESCRIPTION OF LEGEND ITEM "E" SINCE IT IS THE MOST COMMON ENCASEMENT USED FOR ITS DESIGNS. 4. WITHIN THE "REQUIRED ITS ENCASEMENT STANDARD LEGEND" BOX, THE DESCRIPTION OF LEGEND ITEM "E" CAN BE CHANGED TO ANY OF THE OPTIONS FROM THE "REQUIRED ITS ENCASEMENT COMPREHENSIVE LEGEND" BOX OR ALDOT'S "US ITEMS LIST". 5. THE "REQUIRED ITS ENCASEMENT COMPREHENSIVE LEGEND" BOX SHOULD BE USED IF THE ITS DESIGN REQUIRES MORE THAN ONE TYPE OF ENCASEMENT. 6. IF THE "REQUIRED ITS CONDUIT COMPREHENSIVE LEGEND" BOX IS USED, HIDE ANY ITEMS "E01" - "E18" NOT REQUIRED FOR THE ITS DESIGN.			E	6" ELECTRICAL CONDUIT, 1 LINE, TYPE 5 INSTALLATION	E01	2" ELECTRICAL CONDUIT, 1 LINE, TYPE 5 INSTALLATION	E02	3" ELECTRICAL CONDUIT, 1 LINE, TYPE 1 INSTALLATION	E03	3" ELECTRICAL CONDUIT, 2 LINES, TYPE 1 INSTALLATION	E04	3" ELECTRICAL CONDUIT, 1 LINE, TYPE 5 INSTALLATION	E05	3" ELECTRICAL CONDUIT, 2 LINES, TYPE 5 INSTALLATION	E06	4" ELECTRICAL CONDUIT, 1 LINE, TYPE 1 INSTALLATION	E07	4" ELECTRICAL CONDUIT, 2 LINES, TYPE 1 INSTALLATION	E08	4" ELECTRICAL CONDUIT, 4 LINES, TYPE 1 INSTALLATION	E09	4" ELECTRICAL CONDUIT, 1 LINE, TYPE 5 INSTALLATION	E10	4" ELECTRICAL CONDUIT, 2 LINES, TYPE 5 INSTALLATION	E11	5" ELECTRICAL CONDUIT, 2 LINES, TYPE 1 INSTALLATION	E12	5" ELECTRICAL CONDUIT, 1 LINE, TYPE 5 INSTALLATION	E13	5" ELECTRICAL CONDUIT, 2 LINES, TYPE 5 INSTALLATION	E14	6" ELECTRICAL CONDUIT, 1 LINE, TYPE 1 INSTALLATION	E15	6" ELECTRICAL CONDUIT, 1 LINE, TYPE 5 INSTALLATION	E16	6 INCH ELECTRICAL CONDUIT, 2 LINES, TYPE 5 INSTALLATION	E17	8" ELECTRICAL CONDUIT, 1 LINE, TYPE 5 INSTALLATION	E18	8 INCH ELECTRICAL CONDUIT, 3 LINES, TYPE 5 INSTALLATION	REQUIRED ITS FIBER OPTIC STANDARD LEGEND <table><tr><td>06</td><td>FIBER OPTIC DROP CABLE, 6F</td><td>WITH LOCATE TONE WIRE</td></tr><tr><td>12</td><td>FIBER OPTIC DROP CABLE, 12F</td><td>WITH LOCATE TONE WIRE</td></tr><tr><td>24</td><td>FIBER OPTIC TRUNK CABLE, 24F</td><td>WITH LOCATE TONE WIRE</td></tr><tr><td>36</td><td>FIBER OPTIC TRUNK CABLE, 36F</td><td>WITH LOCATE TONE WIRE</td></tr><tr><td>48</td><td>FIBER OPTIC TRUNK CABLE, 48F</td><td>WITH LOCATE TONE WIRE</td></tr><tr><td>60</td><td>FIBER OPTIC TRUNK CABLE, 60F</td><td>WITH LOCATE TONE WIRE</td></tr><tr><td>72</td><td>FIBER OPTIC TRUNK CABLE, 72F</td><td>WITH LOCATE TONE WIRE</td></tr><tr><td>96</td><td>FIBER OPTIC TRUNK CABLE, 96F</td><td>WITH LOCATE TONE WIRE</td></tr><tr><td>14</td><td>FIBER OPTIC TRUNK CABLE, 144F</td><td>WITH LOCATE TONE WIRE</td></tr></table> NOTES: 1. WITHIN THE "REQUIRED ITS FIBER OPTIC STANDARD LEGEND" BOX, HIDE ANY LEGEND ITEMS "06" - "96" NOT REQUIRED FOR THE ITS DESIGN.			06	FIBER OPTIC DROP CABLE, 6F	WITH LOCATE TONE WIRE	12	FIBER OPTIC DROP CABLE, 12F	WITH LOCATE TONE WIRE	24	FIBER OPTIC TRUNK CABLE, 24F	WITH LOCATE TONE WIRE	36	FIBER OPTIC TRUNK CABLE, 36F	WITH LOCATE TONE WIRE	48	FIBER OPTIC TRUNK CABLE, 48F	WITH LOCATE TONE WIRE	60	FIBER OPTIC TRUNK CABLE, 60F	WITH LOCATE TONE WIRE	72	FIBER OPTIC TRUNK CABLE, 72F	WITH LOCATE TONE WIRE	96	FIBER OPTIC TRUNK CABLE, 96F	WITH LOCATE TONE WIRE	14	FIBER OPTIC TRUNK CABLE, 144F	WITH LOCATE TONE WIRE	REQUIRED ITS CONDUCTOR STANDARD LEGEND <table><tr><td>13</td><td>CONDUCTORS, 1 AWG</td><td>(</td><td>2</td><td>EA.</td><td>1</td><td>AWG,</td><td>1</td><td>EA.</td><td>1</td><td>AWG GROUND</td><td>)</td></tr><tr><td>15</td><td>CONDUCTORS, 1 AWG</td><td>(</td><td>3</td><td>EA.</td><td>1</td><td>AWG,</td><td>1</td><td>EA.</td><td>1</td><td>AWG GROUND</td><td>)</td></tr><tr><td>23</td><td>CONDUCTORS, 2 AWG</td><td>(</td><td>2</td><td>EA.</td><td>2</td><td>AWG,</td><td>1</td><td>EA.</td><td>2</td><td>AWG GROUND</td><td>)</td></tr><tr><td>25</td><td>CONDUCTORS, 2 AWG</td><td>(</td><td>3</td><td>EA.</td><td>2</td><td>AWG,</td><td>1</td><td>EA.</td><td>2</td><td>AWG GROUND</td><td>)</td></tr><tr><td>43</td><td>CONDUCTORS, 4 AWG</td><td>(</td><td>2</td><td>EA.</td><td>4</td><td>AWG,</td><td>1</td><td>EA.</td><td>4</td><td>AWG GROUND</td><td>)</td></tr><tr><td>45</td><td>CONDUCTORS, 4 AWG</td><td>(</td><td>3</td><td>EA.</td><td>4</td><td>AWG,</td><td>1</td><td>EA.</td><td>4</td><td>AWG GROUND</td><td>)</td></tr><tr><td>63</td><td>CONDUCTORS, 6 AWG</td><td>(</td><td>2</td><td>EA.</td><td>6</td><td>AWG,</td><td>1</td><td>EA.</td><td>6</td><td>AWG GROUND</td><td>)</td></tr><tr><td>65</td><td>CONDUCTORS, 6 AWG</td><td>(</td><td>3</td><td>EA.</td><td>6</td><td>AWG,</td><td>1</td><td>EA.</td><td>6</td><td>AWG GROUND</td><td>)</td></tr><tr><td>98</td><td colspan="11">*(IF REQUIRED FOR THE ITS DESIGN)</td></tr><tr><td>99</td><td colspan="11">*(IF REQUIRED FOR THE ITS DESIGN)</td></tr></table> ITS CONDUCTOR OPTIONS <table><tr><td>*</td><td>CONDUCTORS, 8 AWG</td><td>(</td><td>#</td><td>EA.</td><td>8</td><td>AWG,</td><td>1</td><td>EA.</td><td>8</td><td>AWG GROUND</td><td>)</td></tr><tr><td>*</td><td>CONDUCTORS, 1/0 AWG</td><td>(</td><td>#</td><td>EA.</td><td>1/0</td><td>AWG,</td><td>1</td><td>EA.</td><td>1/0</td><td>AWG GROUND</td><td>)</td></tr><tr><td>*</td><td>CONDUCTORS, 2/0 AWG</td><td>(</td><td>#</td><td>EA.</td><td>2/0</td><td>AWG,</td><td>1</td><td>EA.</td><td>2/0</td><td>AWG GROUND</td><td>)</td></tr><tr><td>*</td><td>CONDUCTORS, 3/0 AWG</td><td>(</td><td>#</td><td>EA.</td><td>3/0</td><td>AWG,</td><td>1</td><td>EA.</td><td>3/0</td><td>AWG GROUND</td><td>)</td></tr><tr><td>*</td><td>CONDUCTORS, 4/0 AWG</td><td>(</td><td>#</td><td>EA.</td><td>4/0</td><td>AWG,</td><td>1</td><td>EA.</td><td>4/0</td><td>AWG GROUND</td><td>)</td></tr><tr><td>*</td><td>CONDUCTORS, 250 KCMIL</td><td>(</td><td>#</td><td>EA.</td><td>250 KCMIL,</td><td>1</td><td>EA.</td><td>250 KCMIL GROUND</td><td colspan="3"></td></tr><tr><td>*</td><td>CONDUCTORS, 400 KCMIL</td><td>(</td><td>#</td><td>EA.</td><td>400 KCMIL,</td><td>1</td><td>EA.</td><td>400 KCMIL GROUND</td><td colspan="3"></td></tr><tr><td>*</td><td>CONDUCTORS, 500 KCMIL</td><td>(</td><td>#</td><td>EA.</td><td>500 KCMIL,</td><td>1</td><td>EA.</td><td>500 KCMIL GROUND</td><td colspan="3"></td></tr></table> NOTES: 1. ONLY THE "REQUIRED ITS CONDUCTOR STANDARD LEGEND" BOX SHOULD BE SHOWN IN THE PLAN SET. 2. WITHIN THE "REQUIRED ITS CONDUCTOR STANDARD LEGEND" BOX, POPULATE ANY LEGEND ITEMS "98" - "99" REQUIRED FOR THE ITS DESIGN. 3. LEGEND ITEMS "98" - "99" SHOULD BE POPULATED FROM THE "ITS CONDUCTOR OPTIONS" BOX OR ALDOT'S "US ITEMS LIST". 4. IF ANY ITEMS FROM THE "ITS CONDUCTOR OPTIONS" BOX ARE USED, POPULATE ALL " # " REQUIRED FOR THE ITS DESIGN. 5. WITHIN THE "REQUIRED ITS CONDUCTOR STANDARD LEGEND" BOX, HIDE ANY LEGEND ITEMS "13" - "99" NOT REQUIRED FOR THE ITS DESIGN.			13	CONDUCTORS, 1 AWG	(	2	EA.	1	AWG,	1	EA.	1	AWG GROUND	)	15	CONDUCTORS, 1 AWG	(	3	EA.	1	AWG,	1	EA.	1	AWG GROUND	)	23	CONDUCTORS, 2 AWG	(	2	EA.	2	AWG,	1	EA.	2	AWG GROUND	)	25	CONDUCTORS, 2 AWG	(	3	EA.	2	AWG,	1	EA.	2	AWG GROUND	)	43	CONDUCTORS, 4 AWG	(	2	EA.	4	AWG,	1	EA.	4	AWG GROUND	)	45	CONDUCTORS, 4 AWG	(	3	EA.	4	AWG,	1	EA.	4	AWG GROUND	)	63	CONDUCTORS, 6 AWG	(	2	EA.	6	AWG,	1	EA.	6	AWG GROUND	)	65	CONDUCTORS, 6 AWG	(	3	EA.	6	AWG,	1	EA.	6	AWG GROUND	)	98	*(IF REQUIRED FOR THE ITS DESIGN)											99	*(IF REQUIRED FOR THE ITS DESIGN)											*	CONDUCTORS, 8 AWG	(	#	EA.	8	AWG,	1	EA.	8	AWG GROUND	)	*	CONDUCTORS, 1/0 AWG	(	#	EA.	1/0	AWG,	1	EA.	1/0	AWG GROUND	)	*	CONDUCTORS, 2/0 AWG	(	#	EA.	2/0	AWG,	1	EA.	2/0	AWG GROUND	)	*	CONDUCTORS, 3/0 AWG	(	#	EA.	3/0	AWG,	1	EA.	3/0	AWG GROUND	)	*	CONDUCTORS, 4/0 AWG	(	#	EA.	4/0	AWG,	1	EA.	4/0	AWG GROUND	)	*	CONDUCTORS, 250 KCMIL	(	#	EA.	250 KCMIL,	1	EA.	250 KCMIL GROUND				*	CONDUCTORS, 400 KCMIL	(	#	EA.	400 KCMIL,	1	EA.	400 KCMIL GROUND				*	CONDUCTORS, 500 KCMIL	(	#	EA.	500 KCMIL,	1	EA.	500 KCMIL GROUND				REQUIRED ITS COMMBOX STANDARD LEGEND <table><tr><td>L</td><td>1 EA. MISCELLANEOUS INFRASTRUCTURE, COMMBOX, TYPE E1</td></tr><tr><td>M</td><td>1 EA. MISCELLANEOUS INFRASTRUCTURE, COMMBOX, TYPE F# 1 EA. MISCELLANEOUS INFRASTRUCTURE, FIBER MARKER POST # LF FIBER OPTIC TRUNK/DROP CABLE, #F (MAINTENANCE COIL)</td></tr><tr><td>N</td><td>1 EA. MISCELLANEOUS INFRASTRUCTURE, COMMBOX, TYPE F# 1 EA. MISCELLANEOUS INFRASTRUCTURE, FIBER MARKER POST # LF FIBER OPTIC TRUNK/DROP CABLE, #F (MAINTENANCE COIL)</td></tr><tr><td>P</td><td>1 EA. MISCELLANEOUS INFRASTRUCTURE, COMMBOX, TYPE F# 1 EA. MISCELLANEOUS INFRASTRUCTURE, FIBER MARKER POST # LF FIBER OPTIC TRUNK/DROP CABLE, #F (MAINTENANCE COIL)</td></tr><tr><td>R</td><td>1 EA. MISCELLANEOUS INFRASTRUCTURE, COMMBOX, TYPE F# 1 EA. MISCELLANEOUS INFRASTRUCTURE, FIBER MARKER POST # LF FIBER OPTIC TRUNK/DROP CABLE, #F (MAINTENANCE COIL)</td></tr><tr><td>T</td><td>1 EA. MISCELLANEOUS INFRASTRUCTURE, COMMBOX, TYPE F# 1 EA. MISCELLANEOUS INFRASTRUCTURE, FIBER MARKER POST # LF FIBER OPTIC TRUNK/DROP CABLE, #F (MAINTENANCE COIL)</td></tr></table> NOTES: 1. THE "REQUIRED ITS COMMBOX STANDARD LEGEND" BOX IS OPTIONAL. IT IS IS INTENDED TO AID IN THE ITS DESIGN BY REDUCING THE AMOUNT OF CALLOUTS REQUIRED ON EACH PLAN SET. 2. THE "REQUIRED ITS COMMBOX STANDARD LEGEND" BOX IS INTENDED FOR EASE IN CALLING OUT COMMBOXES ON PLAN SHEETS WHERE LONG RUNS OF FIBER OPTIC CABLES AND/OR CONDUCTORS ONLY PASS THROUGH THE REQUIRED COMMBOXES. 3. WITHIN THE "REQUIRED ITS COMMBOX STANDARD LEGEND" BOX, POPULATE ALL " # " REQUIRED FOR THE ITS DESIGN. 4. WITHIN THE "REQUIRED ITS COMMBOX STANDARD LEGEND" BOX, CHOOSE EITHER " TRUNK " OR " DROP " REQUIRED FOR THE ITS DESIGN. 5. WITHIN THE "REQUIRED ITS COMMBOX STANDARD LEGEND" BOX, HIDE ANY ANY LEGEND ITEMS "U" - "Z" NOT REQUIRED FOR THE ITS DESIGN.			L	1 EA. MISCELLANEOUS INFRASTRUCTURE, COMMBOX, TYPE E1	M	1 EA. MISCELLANEOUS INFRASTRUCTURE, COMMBOX, TYPE F# 1 EA. MISCELLANEOUS INFRASTRUCTURE, FIBER MARKER POST # LF FIBER OPTIC TRUNK/DROP CABLE, #F (MAINTENANCE COIL)	N	1 EA. MISCELLANEOUS INFRASTRUCTURE, COMMBOX, TYPE F# 1 EA. MISCELLANEOUS INFRASTRUCTURE, FIBER MARKER POST # LF FIBER OPTIC TRUNK/DROP CABLE, #F (MAINTENANCE COIL)	P	1 EA. MISCELLANEOUS INFRASTRUCTURE, COMMBOX, TYPE F# 1 EA. MISCELLANEOUS INFRASTRUCTURE, FIBER MARKER POST # LF FIBER OPTIC TRUNK/DROP CABLE, #F (MAINTENANCE COIL)	R	1 EA. MISCELLANEOUS INFRASTRUCTURE, COMMBOX, TYPE F# 1 EA. MISCELLANEOUS INFRASTRUCTURE, FIBER MARKER POST # LF FIBER OPTIC TRUNK/DROP CABLE, #F (MAINTENANCE COIL)	T	1 EA. MISCELLANEOUS INFRASTRUCTURE, COMMBOX, TYPE F# 1 EA. MISCELLANEOUS INFRASTRUCTURE, FIBER MARKER POST # LF FIBER OPTIC TRUNK/DROP CABLE, #F (MAINTENANCE COIL)
A	CONDUIT, UNDERGROUND, NON-METALLIC, 2 INCH																																																																																																																																																																																																																																																																																																																																																																			
B	CONDUIT, RIGID METALLIC, 2 INCH																																																																																																																																																																																																																																																																																																																																																																			
C	CONDUIT, UNDERGROUND, NON-METALLIC, 1 1/2 INCH																																																																																																																																																																																																																																																																																																																																																																			
D	CONDUIT, UNDERGROUND, NON-METALLIC, 2 1/2 INCH																																																																																																																																																																																																																																																																																																																																																																			
F	CONDUIT, UNDERGROUND, NON-METALLIC, 3 INCH																																																																																																																																																																																																																																																																																																																																																																			
G	CONDUIT, UNDERGROUND, NON-METALLIC, 3 1/2 INCH																																																																																																																																																																																																																																																																																																																																																																			
H	CONDUIT, UNDERGROUND, NON-METALLIC, 4 INCH																																																																																																																																																																																																																																																																																																																																																																			
J	*(IF REQUIRED FOR THE ITS DESIGN)																																																																																																																																																																																																																																																																																																																																																																			
K	*(IF REQUIRED FOR THE ITS DESIGN)																																																																																																																																																																																																																																																																																																																																																																			
SP	SPARE / EMPTY CONDUIT																																																																																																																																																																																																																																																																																																																																																																			
*	CONDUIT, EXPOSED, NON-METALLIC, 1 1/2 INCH																																																																																																																																																																																																																																																																																																																																																																			
*	CONDUIT, EXPOSED, NON-METALLIC, 2 INCH																																																																																																																																																																																																																																																																																																																																																																			
*	CONDUIT, EXPOSED, NON-METALLIC, 2 1/2 INCH																																																																																																																																																																																																																																																																																																																																																																			
*	CONDUIT, EXPOSED, NON-METALLIC, 3 INCH																																																																																																																																																																																																																																																																																																																																																																			
*	CONDUIT, EXPOSED, NON-METALLIC, 3 1/2 INCH																																																																																																																																																																																																																																																																																																																																																																			
*	CONDUIT, EXPOSED, NON-METALLIC, 4 INCH																																																																																																																																																																																																																																																																																																																																																																			
*	CONDUIT, UNDERGROUND, NON-METALLIC, 5 INCH																																																																																																																																																																																																																																																																																																																																																																			
*	CONDUIT, UNDERGROUND, NON-METALLIC, 6 INCH																																																																																																																																																																																																																																																																																																																																																																			
*	CONDUIT, RIGID METALLIC, 2 INCH, ALUMINUM																																																																																																																																																																																																																																																																																																																																																																			
*	CONDUIT, REINFORCED THERMOSETTING RESIN, 2 INCH																																																																																																																																																																																																																																																																																																																																																																			
*	CONDUIT, FRICTION REDUCTION MULTIDUCT SLEEVES, 2 INCH, 2-CELL																																																																																																																																																																																																																																																																																																																																																																			
*	CONDUIT, FRICTION REDUCTION MULTIDUCT SLEEVES, 2 INCH, 3-CELL																																																																																																																																																																																																																																																																																																																																																																			
*	CONDUIT, FRICTION REDUCTION MULTIDUCT SLEEVES, 4 INCH, 3-CELL																																																																																																																																																																																																																																																																																																																																																																			
*	CONDUIT, FRICTION REDUCTION MULTIDUCT SLEEVES, 6 INCH, 3-CELL																																																																																																																																																																																																																																																																																																																																																																			
E	6" ELECTRICAL CONDUIT, 1 LINE, TYPE 5 INSTALLATION																																																																																																																																																																																																																																																																																																																																																																			
E01	2" ELECTRICAL CONDUIT, 1 LINE, TYPE 5 INSTALLATION																																																																																																																																																																																																																																																																																																																																																																			
E02	3" ELECTRICAL CONDUIT, 1 LINE, TYPE 1 INSTALLATION																																																																																																																																																																																																																																																																																																																																																																			
E03	3" ELECTRICAL CONDUIT, 2 LINES, TYPE 1 INSTALLATION																																																																																																																																																																																																																																																																																																																																																																			
E04	3" ELECTRICAL CONDUIT, 1 LINE, TYPE 5 INSTALLATION																																																																																																																																																																																																																																																																																																																																																																			
E05	3" ELECTRICAL CONDUIT, 2 LINES, TYPE 5 INSTALLATION																																																																																																																																																																																																																																																																																																																																																																			
E06	4" ELECTRICAL CONDUIT, 1 LINE, TYPE 1 INSTALLATION																																																																																																																																																																																																																																																																																																																																																																			
E07	4" ELECTRICAL CONDUIT, 2 LINES, TYPE 1 INSTALLATION																																																																																																																																																																																																																																																																																																																																																																			
E08	4" ELECTRICAL CONDUIT, 4 LINES, TYPE 1 INSTALLATION																																																																																																																																																																																																																																																																																																																																																																			
E09	4" ELECTRICAL CONDUIT, 1 LINE, TYPE 5 INSTALLATION																																																																																																																																																																																																																																																																																																																																																																			
E10	4" ELECTRICAL CONDUIT, 2 LINES, TYPE 5 INSTALLATION																																																																																																																																																																																																																																																																																																																																																																			
E11	5" ELECTRICAL CONDUIT, 2 LINES, TYPE 1 INSTALLATION																																																																																																																																																																																																																																																																																																																																																																			
E12	5" ELECTRICAL CONDUIT, 1 LINE, TYPE 5 INSTALLATION																																																																																																																																																																																																																																																																																																																																																																			
E13	5" ELECTRICAL CONDUIT, 2 LINES, TYPE 5 INSTALLATION																																																																																																																																																																																																																																																																																																																																																																			
E14	6" ELECTRICAL CONDUIT, 1 LINE, TYPE 1 INSTALLATION																																																																																																																																																																																																																																																																																																																																																																			
E15	6" ELECTRICAL CONDUIT, 1 LINE, TYPE 5 INSTALLATION																																																																																																																																																																																																																																																																																																																																																																			
E16	6 INCH ELECTRICAL CONDUIT, 2 LINES, TYPE 5 INSTALLATION																																																																																																																																																																																																																																																																																																																																																																			
E17	8" ELECTRICAL CONDUIT, 1 LINE, TYPE 5 INSTALLATION																																																																																																																																																																																																																																																																																																																																																																			
E18	8 INCH ELECTRICAL CONDUIT, 3 LINES, TYPE 5 INSTALLATION																																																																																																																																																																																																																																																																																																																																																																			
06	FIBER OPTIC DROP CABLE, 6F	WITH LOCATE TONE WIRE																																																																																																																																																																																																																																																																																																																																																																		
12	FIBER OPTIC DROP CABLE, 12F	WITH LOCATE TONE WIRE																																																																																																																																																																																																																																																																																																																																																																		
24	FIBER OPTIC TRUNK CABLE, 24F	WITH LOCATE TONE WIRE																																																																																																																																																																																																																																																																																																																																																																		
36	FIBER OPTIC TRUNK CABLE, 36F	WITH LOCATE TONE WIRE																																																																																																																																																																																																																																																																																																																																																																		
48	FIBER OPTIC TRUNK CABLE, 48F	WITH LOCATE TONE WIRE																																																																																																																																																																																																																																																																																																																																																																		
60	FIBER OPTIC TRUNK CABLE, 60F	WITH LOCATE TONE WIRE																																																																																																																																																																																																																																																																																																																																																																		
72	FIBER OPTIC TRUNK CABLE, 72F	WITH LOCATE TONE WIRE																																																																																																																																																																																																																																																																																																																																																																		
96	FIBER OPTIC TRUNK CABLE, 96F	WITH LOCATE TONE WIRE																																																																																																																																																																																																																																																																																																																																																																		
14	FIBER OPTIC TRUNK CABLE, 144F	WITH LOCATE TONE WIRE																																																																																																																																																																																																																																																																																																																																																																		
13	CONDUCTORS, 1 AWG	(	2	EA.	1	AWG,	1	EA.	1	AWG GROUND	)																																																																																																																																																																																																																																																																																																																																																									
15	CONDUCTORS, 1 AWG	(	3	EA.	1	AWG,	1	EA.	1	AWG GROUND	)																																																																																																																																																																																																																																																																																																																																																									
23	CONDUCTORS, 2 AWG	(	2	EA.	2	AWG,	1	EA.	2	AWG GROUND	)																																																																																																																																																																																																																																																																																																																																																									
25	CONDUCTORS, 2 AWG	(	3	EA.	2	AWG,	1	EA.	2	AWG GROUND	)																																																																																																																																																																																																																																																																																																																																																									
43	CONDUCTORS, 4 AWG	(	2	EA.	4	AWG,	1	EA.	4	AWG GROUND	)																																																																																																																																																																																																																																																																																																																																																									
45	CONDUCTORS, 4 AWG	(	3	EA.	4	AWG,	1	EA.	4	AWG GROUND	)																																																																																																																																																																																																																																																																																																																																																									
63	CONDUCTORS, 6 AWG	(	2	EA.	6	AWG,	1	EA.	6	AWG GROUND	)																																																																																																																																																																																																																																																																																																																																																									
65	CONDUCTORS, 6 AWG	(	3	EA.	6	AWG,	1	EA.	6	AWG GROUND	)																																																																																																																																																																																																																																																																																																																																																									
98	*(IF REQUIRED FOR THE ITS DESIGN)																																																																																																																																																																																																																																																																																																																																																																			
99	*(IF REQUIRED FOR THE ITS DESIGN)																																																																																																																																																																																																																																																																																																																																																																			
*	CONDUCTORS, 8 AWG	(	#	EA.	8	AWG,	1	EA.	8	AWG GROUND	)																																																																																																																																																																																																																																																																																																																																																									
*	CONDUCTORS, 1/0 AWG	(	#	EA.	1/0	AWG,	1	EA.	1/0	AWG GROUND	)																																																																																																																																																																																																																																																																																																																																																									
*	CONDUCTORS, 2/0 AWG	(	#	EA.	2/0	AWG,	1	EA.	2/0	AWG GROUND	)																																																																																																																																																																																																																																																																																																																																																									
*	CONDUCTORS, 3/0 AWG	(	#	EA.	3/0	AWG,	1	EA.	3/0	AWG GROUND	)																																																																																																																																																																																																																																																																																																																																																									
*	CONDUCTORS, 4/0 AWG	(	#	EA.	4/0	AWG,	1	EA.	4/0	AWG GROUND	)																																																																																																																																																																																																																																																																																																																																																									
*	CONDUCTORS, 250 KCMIL	(	#	EA.	250 KCMIL,	1	EA.	250 KCMIL GROUND																																																																																																																																																																																																																																																																																																																																																												
*	CONDUCTORS, 400 KCMIL	(	#	EA.	400 KCMIL,	1	EA.	400 KCMIL GROUND																																																																																																																																																																																																																																																																																																																																																												
*	CONDUCTORS, 500 KCMIL	(	#	EA.	500 KCMIL,	1	EA.	500 KCMIL GROUND																																																																																																																																																																																																																																																																																																																																																												
L	1 EA. MISCELLANEOUS INFRASTRUCTURE, COMMBOX, TYPE E1																																																																																																																																																																																																																																																																																																																																																																			
M	1 EA. MISCELLANEOUS INFRASTRUCTURE, COMMBOX, TYPE F# 1 EA. MISCELLANEOUS INFRASTRUCTURE, FIBER MARKER POST # LF FIBER OPTIC TRUNK/DROP CABLE, #F (MAINTENANCE COIL)																																																																																																																																																																																																																																																																																																																																																																			
N	1 EA. MISCELLANEOUS INFRASTRUCTURE, COMMBOX, TYPE F# 1 EA. MISCELLANEOUS INFRASTRUCTURE, FIBER MARKER POST # LF FIBER OPTIC TRUNK/DROP CABLE, #F (MAINTENANCE COIL)																																																																																																																																																																																																																																																																																																																																																																			
P	1 EA. MISCELLANEOUS INFRASTRUCTURE, COMMBOX, TYPE F# 1 EA. MISCELLANEOUS INFRASTRUCTURE, FIBER MARKER POST # LF FIBER OPTIC TRUNK/DROP CABLE, #F (MAINTENANCE COIL)																																																																																																																																																																																																																																																																																																																																																																			
R	1 EA. MISCELLANEOUS INFRASTRUCTURE, COMMBOX, TYPE F# 1 EA. MISCELLANEOUS INFRASTRUCTURE, FIBER MARKER POST # LF FIBER OPTIC TRUNK/DROP CABLE, #F (MAINTENANCE COIL)																																																																																																																																																																																																																																																																																																																																																																			
T	1 EA. MISCELLANEOUS INFRASTRUCTURE, COMMBOX, TYPE F# 1 EA. MISCELLANEOUS INFRASTRUCTURE, FIBER MARKER POST # LF FIBER OPTIC TRUNK/DROP CABLE, #F (MAINTENANCE COIL)																																																																																																																																																																																																																																																																																																																																																																			
ALABAMA DEPARTMENT OF TRANSPORTATION VERSION: 2026.1 DATE: 08/27/2026 EDITED BY:	PLAN SUBMITTAL	PLANS PREPARED BY:	NOT TO SCALE		SHEET TITLE	ROUTE																																																																																																																																																																																																																																																																																																																																																														
					ITS PLAN LAYOUT LEGEND (NOMENCLATURE)																																																																																																																																																																																																																																																																																																																																																															

CONTACT TRAFFIC DESIGN SECTION - ITS GROUP TO REQUEST THE LATEST MICROSOFT EXCEL FILE.